



歩行距離（屋外出口までの距離）
 経路 ⊙ : 1.82m + 5.96m + 16.00m
 = 23.78m < 60.00m → ○K

室名・範囲	床面積		採光 必要面積		採光 有効開口面積 (W×H)		有効面積	判定	換気 必要面積		換気 有効開口面積 (W×H)		有効面積	判定	排煙 必要面積		排煙 有効開口面積 (W×H)		有効面積	判定	
風除室	6.62		-		-		-	-	-		-		-	-	1/50 0.1324		平12建告-四-二-(2)		-	-	
物販スペース	178.86	183.00	1/20	8.943	AW2: (2.892+2.673) × 1.61/2 AW3: (2.644+2.425) × 1.61/2 AW4: (2.396+2.177) × 1.61/2 AW5: (2.149+1.926) × 1.61/2 AW6: (1.901+1.682) × 1.61/2 AW7: (1.654+1.435) × 1.61/2 AW8: (1.406+1.187) × 1.61/2 AW9: (1.158+0.940) × 1.61/2 AW10: (0.911+0.692) × 1.61/2 AW11: (0.663+0.444) × 1.61/2 AW12: (0.416+0.207) × 1.61/2 AW13: (2.884+2.453) × 1.61/2 AW14: (2.397+1.967) × 1.61/2 AW15: (1.911+1.480) × 1.61/2	4.4798 4.0805 3.6812 3.2755 2.5739 2.4866 2.0873 1.6888 1.2904 0.8911 0.5015 4.2962 3.5130 2.7297	37.5755	OK	1/20	8.943	AW3: (2.644+2.425) × 1.61/2 AW5: (2.149+1.926) × 1.61/2 AW7: (1.654+1.435) × 1.61/2 AW9: (1.158+0.940) × 1.61/2 AW14: (2.397+1.967) × 1.61/2	4.0805 3.2755 2.4866 1.6888 3.5130	15.0444	OK	1/50	3.5772	AW3,5,7,9,14: (W1.61 × H0.50) × 5		4.025	OK	
前室	4.14		-		-		-	-	-		-		-	-	-		-		-	-	
軽食スペース	36.43	50.09	1/20	2.5045	AW17: W3.46 × H1.87		6.4702	OK	1/20	2.5045	AW17: W3.46 × H1.87		6.4702	OK	1/50	1.0018	AW17: (W0.80 × H0.77) × 2		1.232	OK	
厨房	13.66	22.77	-	-	-		-	-	-	-	-		-	-	1/50	0.4554	SD2: (W1.64 × H0.77)		1.2628	OK	
保管庫		56.93	1/20	2.8465	AW16: W1.64 × H1.87 AW18: W3.00 × H1.87		3.0668 8.6768	OK	1/20	2.8465	AW16: W1.64 × H1.87 AW18: W3.00 × H1.87		3.0668 8.6768	OK	1/50	1.1386	AW16: (W0.70 × H0.77) AW18: (W0.70 × H0.77) × 2 SD1: (W0.80 × H0.20) SD2: (W1.64 × H0.77)		0.539 1.078 0.160 1.2628	3.0398	OK
多目的WC		5.17	-	-	-		-	-	-	-	機械換気		-	-	-	-	平12建告-四-二-(2)		-	-	
男子WC		11.17	-	-	-		-	-	-	-	機械換気		-	-	-	-	平12建告-四-二-(2)		-	-	
女子WC		13.04	-	-	-		-	-	-	-	機械換気		-	-	-	-	平12建告-四-二-(2)		-	-	

